

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190221-E98031  
**Report Reference** E98031-19861001  
**Issue Date** 2019-FEBRUARY-21

**Issued to:** GOTTAK S L  
Pujades 77 6  
08005 Barcelona SPAIN

**This certificate confirms that  
representative samples of**

COMPONENT - SWITCHES, APPLIANCE AND SPECIAL  
USE  
See Addendum page

Have been investigated by UL in accordance with the  
component requirements in the Standard(s) indicated on  
this Certificate. UL Recognized components are incomplete  
in certain constructional features or restricted in  
performance capabilities and are intended for installation in  
complete equipment submitted for investigation to UL LLC.

**Standard(s) for Safety:** UL 1054 : the standard for Special Use Switches  
C22.2 No. 55-M1986 : Special Use Switches

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Recognized Component Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190221-E98031  
**Report Reference** E98031-19861001  
**Issue Date** 2019-FEBRUARY-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USR, CNR Special Use Switches, Component.

Cat. No.	Electrical Rating	Temp. (°C)	POL/THR	PP	ENDUR	SPCOA
4RH w/suffixes	12 A, 250 V ac 16 A, 250 V ac 1 hp, 120 V ac 2 hp, 240 V ac	70	1/M	-	6K	1, 2, 3, 5
4RH w/suffixes	12 A, 250 V ac 1 hp, 120 V ac 2 hp, 240 V ac	105	2/M	-	6K	5
4RH w/suffixes	16 A, 250 V ac 1 hp, 120 V ac 2 hp, 240 V ac	105	2/M	-	6K	5
4RH w/suffixes	25 A, 250 V ac 16 A, 250 V ac 1 hp, 120 V ac 2 hp, 240 V ac	105	2/M	-	6K	4, 5



Bruce Mahrenholz, Director North American Certification Program  
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

